

**Summary of Decisions of the Building Committee
Building Committee II 33/2006 held on 22.8.2006**

(a) BCII 1 33/2006

Issue : Proposed composite building with EVA serving less than 25% of the main façade of the building.

Decision : The committee, having considered the existing site situation and FSD's advice, accepted the proposal.

(b) BCII 2 33/2006

Issue : Width of EVA at junction with the public road less than 6m.

Decision : Taking into account the advice of FSD, the committee accepted the EVA at the junction with the public road to have a width of 4.7m subject to the production of documentary proof verifying the width claimed on the plans.

(b) BCII 3 33/2006

Issue : Proposed temporary Asphalt Batching Plant not fully complied with the requirements for FRC and MOE.

Decision : The committee, having agreed that the proposed plant similar to a concrete batching plant, treatment of concrete batching plant, agreed to the non-provision of FRP to the structural members of the plant and non-provision of means of escape of the plant excluding the control room and lavatories subject to no adverse comment for FSD.