

Summary of Decisions of the Building Committee
Building Committee II 35/2006 held on 5.9.2006

(a) BCII 1 35/2006

Issue : Proposed 2-storey maintenance depot to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 35/2006

Issue : Proposed guestrooms with inadequate provision of natural lighting.

Decision : The committee noted that the proposal complied with the openable window requirements and the existing windows could not be enlarged as AMO wished to preserve the external elevation of the heritage building. The committee, having considered the existing building constraint, accepted the reduction in the size of window for the habitation room subject to the provision of artificial lighting.