

**Summary of Decisions of the Building Committee
Building Committee II 45/2006 held on 5.12.2006**

(a) BCII 1 45/2006

Issue : Proposed building served by an existing EVA of inadequate loading capacity.

Decision : Having noted that the subject was a single story temporary activity room in an existing school campus and FSD's advice, the committee accepted the proposed EVA arrangement.