

Summary of Decisions of the Building Committee
Building Committee II 46/2006 held on 12.12.2006

(a) BCII 1 46/2006

Issue : Landing provided in between the two consecutive short ramps in a L-shape.

Decision : The committee considered that for the purpose of interpretation of the Code, para. 4.2.1(d) was applicable to the intermediate landings for ramp in a straight flight while there was a change in direction, the intermediate landing should comply with para. 4.2.1(b).