

**Summary of Decisions of the Building Committee
Building Committee II 47/2006 held on 19.12.2006**

(a) BCII 1 47/2006

Issue : Proposed single-storey temporary building served by an EVA of width less than 6m wide.

Decision : The committee, having noted the site conditions and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 47/2006

Issue : Conversion of a non-domestic building into a hotel building with a TBE room of inadequate size.

Decision : Having considered OFTA's comments, the committee accepted the size of the proposed TBE room.