

**Summary of Decisions of the Building Committee
Building Committee II 5/2007 held on 6.2.2007**

(a) BCII 1 5/2007

Issue : Proposed maintenance hanger served by an EVA of inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(b) BCII 2 5/2007

Issue : Proposed single storey building served by an existing EVA with loading capacity less than 30,000 kg.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.

(c) BCII 3 5/2007

Issue : Non-provision of EVA to a 2-storey single-family house.

Decision : The committee, having considered the existing site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety installations to the satisfaction of FSD.