

**Summary of Decisions of the Building Committee
Building Committee II 6/2007 held on 13.2.2007**

(a) BCII 1 6/2007

Issue : Proposed buildings served by an existing EVA of inadequate loading capacity.

Decision : Having noted that the proposed buildings were single storey buildings and taking into account FSD's advice, the committee accepted the proposed EVA arrangement.

(b) BCII 2 6/2007

Issue : Proposed buildings served by an existing EVA of inadequate loading capacity.

Decision : Having noted that the subject building was single storey building and taking into account FSD's advice, the committee accepted the proposed EVA arrangement.

(c) BCII 3 6/2007

Issue : Proposed 3-storey school extension to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 6/2007

Issue : Proposed temporary building served by an EVA with inadequate width, turning radius and space.

Decision : The committee, having considered FSD's advice, accepted the proposed EVA arrangement for the proposed concrete batching plant.