

**Summary of Decisions of the Building Committee**  
**Building Committee II 8/2007 held on 6.3.2007**

(a) BCII 1 8/2007

Issue : PPE establishment located in a composite building.

Decision : The committee noted that the proposed PPE establishment in the form of a stadium would be physically separated from the other accommodation and separate exit staircases and fireman's lifts would be provided. Hence the committee accepted the proposed PPE establishment located in a composite building subject to the complete separation of the establishment from the remainder of the building with 4 hour FRP and subject to no adverse comments from Police and FSD.