

Summary of Decisions of the Building Committee
Building Committee II 10/2007 held on 20.3.2007

(a) BCII 1 10/2007

Issue : Non-provision of insulation in respect of FRP for lift landing doors of car lifts.

Decision : The committee, having noted that a product meeting the insulation requirement was not available in the market and noting the proposed enhanced fire safety measures, accepted the proposed arrangement subject to provision of enhanced fire safety measures.

(b) BCII 2 10/2007

Issue : Exemption from payment of fees for processing plans.

Decision : Having heard the presentation made by the owner's representatives and having noted the policy and practice on the treatment of similar cases, the committee did not accept the exemption of fees for the processing of plans submitted for approval under the B.O.