

**Summary of Decisions of the Building Committee**  
**Building Committee II 13/2007 held on 17.4.2007**

(a) BCII 1 13/2007

Issue : Non-provision of EVA to a single storey transmission station.

Decision : The committee, having considered the site constraints and FSD's advice, accepted the non-provision of EVA.

(b) BCII 2 13/2007

Issue : Less than 25% of the façade of the staff quarters building served by an EVA.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.