

Summary of Decisions of the Building Committee
Building Committee II 14/2007 held on 25.4.2007

(a) BCII 1 14/2007

Issue : Proposed building served by an EVA with a gradient greater than 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 14/2007

Issue : Non-provision of EVA.

Decision : The committee, having noted the site situation, accepted the non-provision of EVA subject to no adverse comment from FSD on the same.

(c) BCII 3 14/2007

Issue : Proposed disposal of seawater into the storm water system.

Decision : Having considered the special circumstances and the acceptance by EPD and DSD, the committee accepted the proposal.

(d) BCII 4 14/2007

Issue : Proposed institutional building with internal office without provision of natural lighting and ventilation.

Decision : The committee, having considered the design and the nature of the development and the provision of central AC system, accepted the proposal subject to the provision of glazing panels along the internal corridor.