## Summary of Decisions of the Building Committee Building Committee II 15/2005 held on 2.5.2007

## (a) <u>BCII 1 15/2007</u>

Issue : Non-provision of FRP to enclosures for the liftwells and lift landing

doors in a concourse building.

Decision : Noting that the liftwells were within a single compartment, the

committee agreed to the proposal.

## (b) <u>BCII 2 15/2007</u>

Issue : Non-provision of flue apertures for gas water heaters to the bathrooms

in the domestic flats of a composite building.

Decision : Having considered the issue, the committee did not identify any

special circumstances to grant a modification.