

**Summary of Decisions of the Building Committee**  
**Building Committee II 19/2007 held on 29.5.2007**

(a) BCII 1 19/2007

Issue : Proposed single-storey kiosk served by an EVA which was located at a distance of more than 10m.

Decision : The committee, having considered the existing situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 19/2007

Issue : Non-provision of fire separation of voids between basement and the upper storeys.

Decision : The committee was of the view that the proposed works should not result in a situation worse than the current one as far as fire safety standard was concerned.