

Summary of Decisions of the Building Committee
Building Committee II 21/2007 held on 12.6.2007

(a) BCII 1 21/2007

Issue : Proposed repair system at external wall for public housing estate.

Decision : The committee, having considered the subject was a repair system and was not part of the external wall, agreed that B(C)Reg 38(d) was not applicable. The committee however considered that the AP should assess the implication of the failure of the repair system when in fire.