

**Summary of Decisions of the Building Committee  
Building Committee II 22/2007 held on 20.6.2007**

(a) BCII 1 22/2007

Issue : Proposed mini-cinemas in premises having schools in operation.

Decision : The committee, having noted that the Fire Engineering Report had been accepted by the Fire Safety Committee and the low capacity of the mini-cinemas, accepted the proposal.

(b) BCII 2 22/2007

Issue : Non-provision of FRP enclosed walls for a glass lift shaft in a single-family house.

Decision : Accepting that the lifts would be operated within single compartment and the low density of the development, the committee accepted the proposal.