

Summary of Decisions of the Building Committee
Building Committee II 28/2007 held on 31.7.2007

(a) BCII 1 28/2007

Issue : The façade of the building in a distance of more than 10m from the EVA.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 28/2007

Issue : Proposed rain water discharge system via infiltration chamber and soaking away for public housing estate.

Decision : The committee, having noted that the proposed system was initiated for the benefit of adjoining reserve zone area. Having considered the views of the relevant departments, the committee raised no objection to the proposal.