

Summary of Decisions of the Building Committee
Building Committee II 29/2007 (Part I) held on 7.8.2007

(a) BCII 1 29/2007

Issue : Non-provision of refuge floor for 42-storey domestic buildings.

Decision : The committee could not identify justifiable grounds for deviating from the relevant MOE Code hence the committee did not accept the non-provision of refuge floor for the 42-storey domestic buildings.