

Summary of Decisions of the Building Committee
Building Committee II 29/2007 (Part II) held on 8.8.2007

(a) MAII 1 29/2007

Issue : Replacement of an existing metal exit staircase not complying current fire code in terms of width of the staircase and distance from common boundary and unprotected windows.

Decision : While the committee noted the building was a declared monument, the committee would like the AP to present his justifications for the non-compliance with the relevant requirements.