

**Summary of Decisions of the Building Committee**  
**Building Committee II 33/2007 held on 4.9.2007**

(a) BCII 1 33/2007

Issue : Non-provision of EVA to a proposed 3-storey single-family house.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(b) BCII 2 33/2007

Issue : Proposed single-storey structure served by an EVA of inadequate loading capacity, turning circle and without EVA signs.

Decision : Having noted the advice of FSD, the committee accepted the proposed EVA arrangement subject to compliance with minimum loading capacity and headroom stipulated in the Code.