

**Summary of Decisions of the Building Committee**  
**Building Committee II 35/2007 held on 18.9.2007**

(a) BCII 1 35/2007

Issue : Non-provision of fireman lift in the L/G floor housing water tanks and associated pumps.

Decision : The committee, having noted the low fire hazard and FSD's advice, accepted the non-provision of fireman lift to the L/G floor.