

**Summary of Decisions of the Building Committee**  
**Building Committee II 36/2007 held on 25.9.2007**

(a) BCII 1 36/2007

Issue : Proposed extension to a hospital building served by an EVA with a gradient greater than 1:10.

Decision : The committee, having considered the site situation, the use of the building and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.