

**Summary of Decisions of the Building Committee  
Building Committee II 37/2007 held on 2.10.2007**

(a) BCII 1 37/2007

Issue : Non-provision of EVA to the transmission station.

Decision : The committee, having noted the site situation and FSD's verbal advice, accepted the non-provision of EVA.

(b) BCII 2 37/2007

Issue : Proposed student hostels served by an EVA of inadequate turning space.

Decision : Having noted the advice of FSD, the committee accepted the proposed EVA arrangement.

(c) BCII 3 37/2007

Issue : Proposed building served by an EVA with inadequate width and a gradient greater than 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(d) BCII 4 37/2007

Issue : Non-provision of 1 hour FRP to the raised floor of a shop.

Decision : The committee, having considered the height of the raised floor, accepted the non-provision of the FRP painting.