

**Summary of Decisions of the Building Committee**  
**Building Committee II 41/2007 held on 30.10.2007**

(a) BCII 1 41/2007

Issue : Proposed transit hotel with some of the internal guestrooms without provision of natural lighting and ventilation and some other guestrooms without provision of natural ventilation.

Decision : The committee, having considered the case, did not accept the application for non-provision of natural lighting and ventilation.

(b) BCII 2 41/2007

Issue : Proposed 7-storey chapel to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(c) BCII 3 41/2007

Issue : (i) The major facade of the proposed extension building being located at a distance of more than 10m from the EVA.

(ii) The distance from the fire service access point to the fireman's lift was more than 18m.

Decision : (i) The committee, having noted the site situation and the proposed enhance fire safety measures, accepted the EVA arrangement subject to the acceptance of the same by FSD.

(ii) The committee, having considered the site situation, accepted the proposed arrangement subject to the acceptance of the same by FSD.

(d) BCII 4 41/2007

Issue : Proposed school extension served by an EVA of inadequate loading capacity.

Decision : Having noted the site situation and advice of FSD, the committee accepted the proposed EVA arrangement.