

**Summary of Decisions of the Building Committee
Building Committee II 45/2007 held on 27.11.2007**

(a) BCII 1 45/2007

Issue : Non-provision of EVA to two 3-storey single family house.

Decision : The committee, having noted the topographical constraint of the area and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures to the satisfaction of FSD.

(b) BCII 2 45/2007

Issue : Lowermost 150mm of the protective barriers at staircase not built solid

Decision : The committee, having noted the design of the staircase, agreed that B(C)R 8(3) was not applicable for the case.