

**Summary of Decisions of the Building Committee  
Building Committee II 1/2008 held on 8.1.2008**

(a) BCII 1 1/2008

- Issue : (i) Proposed single-storey substation to be served by an EVA of inadequate width.
- (ii) Unprotected steelwork construction for the substation located less than 6m from site boundary.
- Decision : (i) The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.
- (ii) The committee noted that the substation would be provided with an RC fence wall of 3m high with an FRP of 2 hours. Agreeing that the proposal would achieve the same objective as required by FRC Code 6.3, the committee allowed the unprotected steel work for the single storey substation and hence accepted the proposal.