

**Summary of Decisions of the Building Committee
Building Committee II 4/2008 held on 29.1.2007**

(a) BCII 1 4/2008

Issue : Non-provision of FRP enclosed walls for a glass lift shaft in the same compartment of a clubhouse.

Decision : Noting that the lifts would be operated within the same compartment of the clubhouse, the committee accepted the proposal.

(b) BCII 2 4/2008

Issue : Provision of openable window for ventilating the lobby of the fireman's lift.

Decision : The committee, having noted FSD's advice, accepted the proposal.