

Summary of Decisions of the Building Committee
Building Committee II 8/2008 held on 4.3.2008

(a) BCII 1 8/2008

Issue : Provision of refuge floor for 42-storey domestic buildings.

Decision : Having noted the special site constraints and the open design of the M/F, the committee considered the M/F could be regarded as the ultimate place of safety and agreed to treat the M/F as ground storey for the purpose of MOE Code 21.1 & 21.5.