

Summary of Decisions of the Building Committee
Building Committee II 13/2008 held on 22.4.2008

(a) BCII 1 13/2008

- Issue : Proposed buildings served by an existing EVA of inadequate width and turning circle and that less than 25% of the perimeter of building would be served by that EVA.
- Decision : Having noted that the site situation and FSD's advice, the committee accepted the proposed EVA arrangement subject to provision of enhance fire safety measures to FSD's satisfaction.