

Summary of Decisions of the Building Committee
Building Committee II 14/2008 held on 29.4.2008

(a) BCII 1 14/2008

- Issue : Proposed refuse storage & material recovery chamber building and recreational building, both single-storey, to be served by an EVA with portion of which less than 7.3m wide and less than 25% of the perimeter of the buildings to be served by an EVA was located at a distance of more than 10m.
- Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement.