

**Summary of Decisions of the Building Committee
Building Committee II 18/2008 held on 27.5.2008**

(a) BCII 1 18/2008

Issue : Non-provision of EVA for single family house.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(b) BCII 2 18/2008

Issue : Proposed commercial building to be served by an EVA of inadequate width and steeper gradient.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to provision of enhanced fire safety measures.