

**Summary of Decisions of the Building Committee
Building Committee II 21/2008 held on 17.6.2008**

(a) BCII 1 21/2008

Issue : Non-provision of EVA to the domestic building not accessible by fire engines.

Decision : The committee, having noted the existing site topographic constraint and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(b) BCII 2 21/2008

Issue : The distance from the fire service access point to the fireman's lift was more than 18m.

Decision : The committee noted that the fire safety provisions for the building was designed with a fire engineering concept of which a Fire Engineering Report had been considered by the Fire Safety Committee. The committee also noted FSD had verbally indicated acceptance of the proposed arrangement. Hence, the committee accepted the same subject to the written confirmation of acceptance of the deviation by FSD.