

**Summary of Decisions of the Building Committee**  
**Building Committee II 23/2008 held on 15.7.2008**

(a) BCII 1 23/2008

Issue : Proposed conversion of commercial use to office use on the 2/F of an existing building with inadequate natural lighting and ventilation.

Decision : The committee, having considered the existing site constraint, accepted the reduction in the glazed area and openable window for the proposed office subject to the provision of artificial lighting and central air conditioning to the satisfaction of the BA.

(b) BCII 2 23/2008

Issue : Replacement of a conventional urinal with a waterfree urinal.

Decision : The committee, having noted that the proposed waterfree urinal required special treatment in terms of operation and maintenance, agreed to defer a decision pending further information on the proposed operation and maintenance in future.