

Summary of Decisions of the Building Committee
Building Committee II 24/2008 held on 22.7.2008

(a) Matters Arising on BCII 2 23/2008

Issue : Replacement of a conventional urinal with a waterfree urinal.

Decision : The committee, having heard the presentation made by the AP, agreed that the AP should provide further information on the following for further consideration: - (i) demonstrating that the same health standard would be maintained for the waterfree urinal; (ii) the effect in case of having a back pressure problem; (iii) clarifying if conditions were imposed in overseas countries for adopting waterfree urinal; and (iv) details of maintenance and management of the proposed urinal for the subject premises.