

Summary of Decisions of the Building Committee
Building Committee II 25/2008 held on 29.7.2008

(a) BCII 1 25/2008

Issue : Non-provision of EVA to a residential building.

Decision : The committee noted that FSD had no objection to the non-provision of EVA subject to the provision of enhanced fire safety installation. However, the committee, having noted that the proposed development intensity had not been accepted by the BA, considered that it was premature to grant modification to permit the non-provision of EVA for the proposed development.

(b) BCII 2 25/2008

Issue : Non-provision of EVA to single-family houses.

Decision : The committee, having considered the site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.