

**Summary of Decisions of the Building Committee  
Building Committee II 28/2008 held on 19.8.2008**

(a) BCII 1 28/2008

Issue : Proposed single storey plant building served by an EVA with inadequate turning circle.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.

(b) BCII 2 28/2008

Issue : Inadequate openable window provision under B(P)Reg 36 for sinks in the guestrooms of a hotel conversion.

Decision : The committee, having considered the existing site constraint and noted that the hotel would be provided with central A/C system, agreed to grant a modification for the non-compliance of B(P)Reg 36(2)(b).