

**Summary of Decisions of the Building Committee
Building Committee II 29/2008 held on 26.8.2008**

(a) BCII 1 29/2008

Issue : The major façade of the single storey changing room and plant room be more than 10m from the EVA.

Decision : Having noted the use of the buildings and FSD's advice, the committee accepted the EVA arrangement.

(b) BCII 2 29/2008

Issue : Non-provision of EVA to the domestic building.

Decision : The committee, having noted the existing site topographic constraint and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(c) BCII 3 29/2008

Issue : Proposed composite building to be served by an EVA of inadequate width and steeper gradient.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to provision of enhanced fire safety measures.