

**Summary of Decisions of the Building Committee
Building Committee II 32/2008 held on 23.9.2008**

(a) BCII 1 32/2008

Issue : Proposed residential building to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 32/2008

Issue : Non-provision of EVA for single family houses.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.

(c) BCII 3 32/2008

Issue : Proposed factory building could not served by an EVA at opposite façades.

Decision : The committee, having considered the site situation, the design of the proposed open-sided single story building and FSD's advice, accepted the proposed EVA arrangement.

(d) BCII 4 32/2008

Issue : Proposed houses development to be served by an EVA of gradient steeper than 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to the provision of enhanced fire safety measures.