

Summary of Decisions of the Building Committee
Building Committee II 33/2008 held on 30.9.2008

(a) BCII 1 33/2008

Issue : Proposed 3-storey residential building to be served by an EVA of inadequate width and with portion of gradient of the EVA in excess of 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to provision of enhanced fire safety measures.

(b) BCII 2 33/2008

Issue : Less than 25% of the facade of the proposed building located within 10m of the EVA.

Decision : The committee, having studied the case, accepted the proposed EVA arrangement subject to the acceptance of the same by FSD.