

Summary of Decisions of the Building Committee
Building Committee II 35/2008 held on 14.10.2008

(a) MAII 1 35/2008

Issue : Replacement of a conventional urinal with a waterfree urinal.

Decision : The committee noted that the manufacturer had provided test reports and research studies on the performance of waterfree urinal in terms of hygiene standards. The committee also noted the views expressed by the AP and the manufacturer that back pressure problem, if any, could be addressed by the provision of an antisiphonic pipe in the drainage system and that the cartridge would not pose environmental hazard for its disposal. Noting that the manufacturer would provide further information on the relevant regulation/ code in overseas countries on the adoption of a waterfree urinal, the committee agreed to defer a decision.