

**Summary of Decisions of the Building Committee
Building Committee II 38/2008 held on 25.11.2008**

(a) MAII 1 38/2008

Issue : Replacement of a conventional urinal with a waterfree urinal.

Decision : The committee noted that the manufacturer had provided relevant regulation/codes in relation to the waterfree urinal in oversea countries. The committee would defer a decision pending the drawing up of the conditions for the approval of the use of waterfree urinal.

(b) BCII 1 38/2008

Issue : Substandard EVA to a proposed domestic building.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the substandard EVA subject to the provision of enhanced fire safety measures.

(c) BCII 2 38/2008

Issue : Proposed building served by an EVA with inadequate width and a gradient greater than 1:10.

Decision : The committee, having considered the site situation and FSD's verbal advice, accepted the proposed EVA arrangement subject to written confirmation from FSD on the acceptance of the same and the provision of enhanced fire safety measures as required by FSD.

(d) BCII 3 38/2008

Issue : Proposed single-storey kiosk to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement.