

**Summary of Decisions of the Building Committee
Building Committee II 40/2008 held on 9.12.2008**

(a) BCII 1 40/2008

Issue : That part of the extension of a school building would be of more than 60m from a fireman's lift.

Decision : The committee, having considered FSD's advice, accepted the proposed arrangement.