

Summary of Decisions of the Building Committee
Building Committee II 4/2009 held on 10.2.2009

(a) BCII 1 4/2009

Issue : Proposed single-storey recreational facilities located on a podium floor of a residential development were not served with a EVA.

Decision : The committee, having considered the FSD' advice, accepted the proposal subject to the provision of enhanced fire safety measures.

(b) BCII 2 4/2009

Issue : Omission of refuse storage and material recovery room (RS & MRR) on typical residential floors.

Decision : The committee noted that the trial piles which would form part of the permanent pile foundation had been approved and completed on site. Having considered the case, the committee agreed to grant a modification for the omission of the RS&MRR on typical residential floor.