

**Summary of Decisions of the Building Committee  
Building Committee II 6/2009 held on 24.2.2009**

(a) BCII 1 6/2009

Issue : Proposed domestic building served by an EVA of inadequate width and steep gradient at some points.

Decision : The committee, having considered the site situation and FSD's verbal advice, accepted the proposed EVA arrangement subject to acceptance of the same by FSD in writing.

(b) BCII 2 6/2009

Issue : Non-provision of EVA for a shelter at the open landscaped area.

Decision : The committee, having noted the site situation and FSD's verbal advice, accepted the non-provision of EVA subject to the acceptance of the same by FSD in writing.

(c) BCII 3 6/2009

Issue : Non-provision of EVA for 3-storey composite building.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures to the satisfaction of DFS.