

Summary of Decisions of the Building Committee
Building Committee II 9/2009 held on 17.3.2009

(a) BCII 1 9/2009

Issue : The distance from the fire service access point to the fireman's lift was more than 18m.

Decision : The committee, having noted the need to preserve the existing facade and FSD's advice, accepted the location of the proposed fireman's lift.