

**Summary of Decisions of the Building Committee  
Building Committee II 12/2009 held on 7.4.2009**

(a) BCII 1 12/2009

Issue : Proposed perforated ceiling next to an escalator void.

Decision : Having noted the site constraint on low headroom and the proposed false ceiling would have a perforation of not less than 70%, evenly distributed opening, the committee accepted the proposal under FRC Code 12.1.

(b) BCII 2 12/2009

Issue : Non-provision of EVA to the single-storey transformer room and switch room.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA.

(c) BCII 3 12/2009

Issue : Non-provision of EVA to the single-storey pump room with sprinkler system and FS water tanks.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA.