

**Summary of Decisions of the Building Committee
Building Committee II 13/2009 held on 15.4.2009**

(a) BCII 1 13/2009

Issue : EVA to be steeper than 1 in 10.

Decision : The committee, having noted the site situation and FSD's advice, accepted the deficiency of the EVA subject to compliance with FSD's requirements.

(b) BCII 2 13/2009

Issue : EVA cannot serve two opposite facades of a warehouse.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the deficiency of the EVA subject to compliance with FSD's requirements.

(c) BCII 3 13/2009

Issue : Non-provision of EVA to the single-storey pump room with sprinkler system and FS water tanks.

Decision : The committee, having noted the scale of the works and FSD's advice, accepted the non-provision of EVA.