

Summary of Decisions of the Building Committee
Building Committee II 16/2009 held on 5.5.2009

(a) BCII 1 16/2009

Issue : Proposed plant development to be served by an EVA of inadequate width.

Decision : The committee, having considered FSD's verbal advice, accepted the proposed EVA arrangement subject to the written confirmation of the same from FSD and the provision of enhanced fire safety measures to the satisfaction of FSD.

(b) BCII 2 16/2009

Issue : The distance of the fireman's lifts from part of the floors of the proposed school was more than 60m.

Decision : The committee, having considered FSD's advice, accepted the proposed arrangement.

(c) BCII 3 16/2009

Issue : Non-provision of EVA to single-family houses.

Decision : The committee, having noted the site constraint and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures.