

**Summary of Decisions of the Building Committee
Building Committee II 18/2009 held on 2.6.2009**

(a) BCII 1 18/2009

Issue : Proposed single storey factory building to be served by an EVA with inadequate width.

Decision : The committee, having noted the site situation and FSD's advice, accepted the EVA arrangement subject to the provision of enhanced fire safety measures.

(b) BCII 2 18/2009

Issue : Proposed residential building to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation, accepted the proposed EVA arrangement subject to acceptance of the same by FSD.

(c) BCII 3 18/2009

Issue : Proposed building served by an EVA with inadequate width and without a proper turning circle and a gradient greater than 1:10.

Decision : The committee, having considered the site situation and FSD's advice, accepted the proposed EVA arrangement subject to acceptance of the same by FSD.

(d) BCII 4 18/2009

Issue : Non-provision of EVA for single family house.

Decision : The committee, having noted the site situation and FSD's advice, accepted the non-provision of EVA subject to the provision of enhanced fire safety measures to FSD's satisfaction.