

**Summary of Decisions of the Building Committee  
Building Committee II 19/2009 held on 9.6.2009**

(a) BCII 1 19/2009

Issue : Lift landing doors have 1 hour FRP protection with regard to integrity only for single family houses.

Decision : Accepting that the lifts would be operated within single compartment and taking into account that the houses were for single family use, the committee accepted the proposal.

(b) BCII 2 19/2009

Issue : Proposed factory building to be served by an EVA of inadequate width.

Decision : The committee, having considered the site situation and the verbal advice of FSD & TD, accepted the proposed EVA arrangement subject to written confirmation from FSD & TD on the same and the provision of enhanced fire safety measures to FSD's satisfaction.