

Summary of Decisions of the Building Committee
Building Committee II 21/2009 held on 23.6.2009

(a) BCII 1 21/2009

Issue : Proposed single storey transformer rooms served by an existing EVA of inadequate width, turning circle and headroom.

Decision : Having noted that the site situation, the committee accepted the proposed EVA arrangement subject to no objection from FSD.